

333 Bayview Avenue Amityville, New York 11701 For Sales and Repairs, (800) 645-9445 For Technical Service, (800) 645-9440 Publicly traded on NASDAQ Symbol: NSSC

# GEMC-WL-HEAT Wireless Heat Detector with Rate of Rise INSTALLATION INSTRUCTIONS

© NAPCO 2010 WI1744B 08/10

### **DESCRIPTION**

The GEMC-WL-HEAT is a high-quality 135°F (57°C) fixed temperature detector with Rate of Rise. It is compatible with Napco's GEM-RECV and GEMC-RECV Series supervised receivers that monitor alarms, restores, low battery, tamper and status. **Note:** See Control Unit installation instructions for compatibility.

The GEMC-WL-HEAT incorporates circuitry which will transmit an alarm signal upon an alarm condition, generate an hourly supervision test signal to the receiver and also monitor and annunciate low battery.

Coding switches are not required or used in the GEMC-WL-HEAT. Each transmitter is assigned a unique identification code number at the factory. The transmitter is powered by one 3V Lithium battery (supplied) which can power the unit for up to two years. If the battery voltage drops below normal, a low-battery report will be sent to the receiver with any status or alarm transmission. If a low-battery condition is indicated, replace the battery.

### **OPERATION**

**Rate-of-Rise Feature:** A temperature increase of 15°F or more per minute will result in an alarm transmission. When the rate-of-rise element alone has been activated, the detector is self-restoring.


**Fixed Temperature:** If the temperature of the center disk rises to the detector's rated temperature (135°F / 57°C) an alarm transmission will result. When actuated by the fixed temperature element, the detector is non-restorable and must be replaced. The need for replacement is indicated when the center disk has fallen free. Order Edwards Model 281B-PL or GE Model 104-13 to replace detector.

When the GEMC-WL-HEAT detects an alarm as described above, the integral transmitter will send an alarm signal to the receiver. The alarm signal will be repeated every 10 seconds thereafter as long as the alarm condition is present. A restore report will be sent when the condition clears. Supervision status reports are sent from the GEMC-WL-HEAT every hour.

### WARNING: NOT A LIFE SAFETY DEVICE - USE FOR PROPERTY PROTECTION ONLY


### Step 1. Remove the mounting base.

Lift the GEMC-WL-HEAT from the base by turning the heat detector counter-clockwise while holding the base stationary.



### Step 2. Locate the RF ID#

Locate the RF ID# on the circuit board. **NOTE:** The RF ID# that appears on the circuit board label must be recorded in order to map the transmitter into the system. (see Step 7).




### Step 3. Install the battery

Observing polarity, install the supplied battery as shown.

**NOTE:** If the Auto-Enroll technique is to be used to map the transmitter, it must be done at the point the battery is installed. (Consult the control panel installation instructions for the Auto-Enroll procedure).

**NOTE:** Replace battery with a 3V Duracell DL123A, Varta / Power-One CR123A or Panasonic CR123A only. Use of another battery may present a risk of fire or explosion.



**BATTERY CAUTION:** Risk of Fire, explosion and burns. Do not recharge, disassemble, heat above 100°C., or incinerate. Dispose of used batteries promptly. Keep away from children.


### Step 4. Mounting the base to the ceiling

Select mounting location for detector on ceiling. Do not locate in direct path of hot or cold air flow. Remove the protective insert from the base. Use the two screws and anchors provided to attach the mounting plate to the wall or ceiling.

Reinstall the the protective insert into the base.

**NOTE:** The mounting plate may be attached to a *plastic* singlegang electrical outlet box. Do not attach to metallic outlet boxes.

The GEMC-WL-HEAT must be affixed to a fixed structural member, not to a removable ceiling tile or other flexible surface.



### Step 5. Align the GEMC-WL-HEAT with the mounting plate.

Carefully align the mounting screws with the mounting holes in the base. Be sure the tamper tab inside the mounting plate is aligned

with--and presses down on--the tamper switch when installing (see image at right) and by aligning the two green dots.




### Step 7. Map the GEMC-WL-HEAT Transmitter

Referring to the installation instructions for the control panel and keypad in use, enter the following:

- The zone to which the transmitter will be mapped. Note: This zone must be programmed as a Fire Zone as per the control panel installation instructions;
- The 6-digit RF identification number / 1 digit checksum number printed on the transmitter (include all numbers and/or letters and leading zeros, if any);
- The transmitter point number ("1").

# **Step 6.** Reinstall the GEMC-WL-HEAT into the mounting plate. Push down and turn clockwise until the GEMC-WL-HEAT is secured in place.



### Step 8. Testing the system

Test system with unit mounted. If the system is monitored, notify central station of impending test.

The rate-of-rise feature may be tested by a quick application of heat from any convenient source. A portable hair dryer is recommended. However, do not apply heat which exceeds the fixed temperature rating of the detector. If the fixed temperature is exceeded, the center disk of the detector will drop and the detector must be replaced.

Apply the heat until the local alarm sounds. Verify that the GEMC-WL-HEAT has triggered the correct zone and that the correct report has been transmitted to central station. Wait a few minutes and reset the fire circuit. Insure that the system returns to a normal status.

### **SPECIFICATIONS**

# Electrical Ratings Input Power:

Powered by a 3-volt lithium battery.

Fixed Temperature Point: 135°F (57°C).

Operating Frequency: 319.5Mhz

#### WARNINGS

- HEAT DETECTORS ARE NOT LIFE SAFETY DEVICES: USE FOR PROPERTY PROTECTION ONLY.
- WHERE LIFE SAFETY IS REQUIRED, SMOKE DETECTORS MUST ALSO BE USED.
- BATTERY BACK-UP: HEAT DETECTORS SHOULD BE ELECTRONICALLY SUPERVISED WITH BATTERY BACKUP AT THE PANEL.
- THE RATE-OF-RISE MECHANISM MAYBE SUBJECT TO REDUCED SENSITIVITY OVER TIME. ANNUAL TESTING OF THE RATE-OF-RISE OPERATION IS RECOMMENDED.
- REFER TO NFPA STANDARD 72 FOR APPLICATION REQUIREMENTS, TESTING AND MAINTENANCE.
- DO NOT PAINT THE GEMC-WL-HEAT.
- A TAMPER ZONE TROUBLE WILL RESULT WHEN THE BATTERIES ARE REPLACED.

### **FCC STATEMENT**

**CAUTION:** Changes or modifications not expressly approved by Napco Security Systems could void the user's authority to operate the equipment.

### RADIO AND TELEVISION INTERFERENCE

This equipment has been tested and found to comply with the limits for a Class B Digital Device, pursuant to Part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference in residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:


- Reorient or relocate the receiver antenna.
- Increase the separation between the equipment and the receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

You may also find helpful the following booklet, prepared by the FCC: "How to Identify and Resolve Radio-TV Interference Problems." This booklet is available from the U.S. Government Printing Office, Washington D.C. 20402.

Changes and Modifications not expressly approved by the manufacturer or registrant of this equipment can void your authority to operate this equipment under Federal Communications Commissions rules.

### **Additional Warnings:**

- 1. This device may not cause interference.
- 2. This device must accept any interference, including interference that may cause undesired operation of the device.



## NAPCO LIMITED WARRANTY

NAPCO SECURITY SYSTEMS, INC. (NAPCO) warrants its products to be free from manufacturing defects in materials and workmanship for *thirty-six months* following the date of manufacture. NAPCO will, within said period, at its option, repair or replace any product failing to operate correctly without charge to the original purchaser or user.

This warranty shall not apply to any equipment, or any part thereof, which has been repaired by others, improperly installed, improperly used, abused, altered, damaged, subjected to acts of God, or on which any serial numbers have been altered, defaced or removed. Seller will not be responsible for any dismantling or reinstallation charges.

THERE ARE NO WARRANTIES, EXPRESS OR IMPLIED, WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF. THERE IS NO EXPRESS OR IMPLIED WARRANTY OF MERCHANTABILITY OR A WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE. ADDITIONALLY, THIS WARRANTY IS IN LIEU OF ALL OTHER OBLIGATIONS OR LIABILITIES ON THE PART OF NAPCO.

Any action for breach of warranty, including but not limited to any implied warranty of merchantability, must be brought within the six months following the end of the warranty period. IN NO CASE SHALL NAPCO BE LIABLE TO ANYONE FOR ANY CONSEQUENTIAL OR INCIDENTAL DAMAGES FOR BREACH OF THIS OR ANY OTHER WARRANTY, EXPRESS OR IMPLIED, EVEN IF THE LOSS OR DAMAGE IS CAUSED BY THE SELLER'S OWN NEGLIGENCE OR FAULT.

In case of defect, contact the security professional who installed and maintains your security system. In order to exercise the warranty, the product must be returned by the security professional, shipping costs prepaid and insured to NAPCO. After repair or replacement, NAPCO assumes the cost of returning products under warranty. NAPCO shall have no obligation under this warranty, or otherwise, if the product has been repaired by others, improperly installed, improperly used, abused, altered, damaged, subjected to accident, nuisance, flood, fire or acts of God, or on which any serial numbers have been altered, defaced or removed. NAPCO will not be responsible for any dismantling, reassembly or reinstallation charges.

This warranty contains the entire warranty. It is the sole warranty and any prior agreements or representations, whether oral or written, are either merged herein or are expressly cancelled. NAPCO neither assumes, nor authorizes any other person purporting to act on its

behalf to modify, to change, or to assume for it, any other warranty or liability concerning its products.

In no event shall NAPCO be liable for an amount in excess of NAPCO's original selling price of the product, for any loss or damage, whether direct, indirect, incidental, consequential, or otherwise arising out of any failure of the product. Seller's warranty, as hereinabove set forth, shall not be enlarged, diminished or affected by and no obligation or liability shall arise or grow out of Seller's rendering of technical advice or service in connection with Buyer's order of the goods furnished hereunder.

NAPCO RECOMMENDS THAT THE ENTIRE SYSTEM BE COMPLETELY TESTED WEEKLY.

Warning: Despite frequent testing, and due to, but not limited to, any or all of the following; criminal tampering, electrical or communications disruption, it is possible for the system to fail to perform as expected. NAPCO does not represent that the product/system may not be compromised or circumvented; or that the product or system will prevent any personal injury or property loss by burglary, robbery, fire or otherwise; nor that the product or system will in all cases provide adequate warning or protection. A properly installed and maintained alarm may only reduce risk of burglary, robbery, fire or otherwise but it is not insurance or a guarantee that these events will not occur. CONSEQUENTLY, SELLER SHALL HAVE NO LIABILITY FOR ANY PERSONAL INJURY. PROPERTY DAMAGE, OR OTHER LOSS BASED ON A CLAIM THE PRODUCT FAILED TO GIVE WARNING. Therefore, the installer should in turn advise the consumer to take any and all precautions for his or her safety including, but not limited to, fleeing the premises and calling police or fire department, in order to mitigate the possibilities of harm and/or damage.

NAPCO is not an insurer of either the property or safety of the user's family or employees, and limits its liability for any loss or damage including incidental or consequential damages to NAPCO's original selling price of the product regardless of the cause of such loss or damage.

Some states do not allow limitations on how long an implied warranty lasts or do not allow the exclusion or limitation of incidental or consequential damages, or differentiate in their treatment of limitations of liability for ordinary or gross negligence, so the above limitations or exclusions may not apply to you. This Warranty gives you specific legal rights and you may also have other rights which vary from state to state.